

March 1, 2016

Mr. Will Rosquist
Administrator
Montana Public Service Commission
1701 Prospect Avenue
PO Box 202601
Helena, MT 59620-2601

RE: 2015 Annual Electric Reliability Report

Dear Mr. Rosquist:

With this letter, NorthWestern Energy (NWE) submits the 2015 Reliability Report in compliance with Administrative Rules of Montana 38.5.8619 Annual Electric Reliability Report, effective on July 29, 2005. The data provided in this report includes the information requested in ARM 38.5.8619 and utilizes the *IEEE Guide for Electric Power Distribution Reliability Indices (IEEE Std. 1366-2012)* for definition of major events and the appropriate reliability indices. Similar to the previous four years, additional transmission line reliability information is attached to the report.

Please contact me to answer any questions concerning this report. My contact information is as follows:

Bill Bowden
Technical Advisor, Senior
NorthWestern Energy
11 East Park Street
Butte, Montana 59701
(406) 497-2211
william.bowden@northwestern.com

Sincerely,

Bill Bowden, P.E.
Technical Advisor, Senior

Enclosure: 2015 Annual Electric Reliability Report

NorthWestern[®] Energy

***2015
-Montana-
Electric Distribution/Transmission
Annual Reliability Report***



March 2016

TABLE OF CONTENTS

EXECUTIVE SUMMARY	3
1. GENERAL.....	4
2. MONTANA SYSTEM RELIABILITY	6
3. BILLINGS SYSTEM RELIABILITY.....	10
4. BOZEMAN SYSTEM RELIABILITY	14
5. BUTTE SYSTEM RELIABILITY	18
6. GREAT FALLS SYSTEM RELIABILITY.....	22
7. HAVRE SYSTEM RELIABILITY	26
8. HELENA SYSTEM RELIABILITY	30
9. LEWISTOWN SYSTEM RELIABILITY.....	34
10. MISSOULA SYSTEM RELIABILITY	38
11. CONCLUSION.....	42
ANNEX A: TRANSMISSION DATA AND GRAPHS	43

EXECUTIVE SUMMARY

This report provides information and insights into NorthWestern Energy's (NWE) 2015 Electric Distribution and Transmission System reliability indices for the Montana region, in accordance with the guidelines outlined by the Administrative Rules of Montana (Rule 38.5.8619). The indices included are **SAIDI** (System Average Interruption Duration Index – in minutes), **CAIDI** (Customer Average Interruption Duration Index – in minutes), **SAIFI** (System Average Interruption Frequency Index – in frequency) and **Outage Counts**. By the IEEE standard definitions, these indices are for “sustained interruptions” meaning they lasted longer than five minutes.

System indices are given for the NWE Montana operating region and are also broken down into the eight operating areas of the state: Billings, Bozeman, Butte, Great Falls, Havre, Helena, Lewistown, and Missoula. As with the previous years' annual reports, the Institute of Electrical and Electronics Engineers (IEEE) Standard 1366-2012 will again be followed. This standard is directly related to the use of a statistically based definition for classification of Major Event Days (MEDs) – also commonly referred to as the 2.5 Beta Method. Major Event Days are days in which the regional SAIDI exceeds a statistically derived threshold value and represent days in which the electric system experienced stresses beyond normal operating conditions (such as a severe weather storm) and often requiring additional crews be brought into the area for repairs.

The InService mobile work force and outage management system was implemented by NWE during the fall of 2014. This provides more accurate and timely outage reporting. Outage customer counts and times are derived from the GIS, call logging, and automated systems, eliminating the earlier manual outage reporting system and its inherent approximations. Both IEEE and the Department of Energy reports indicate that SAIDI numbers normally increase with this improved accuracy, but with the whims of nature, this may be difficult to determine for some time. The IEEE reliability standard (1366-2012) does not define the 24 hour day and many of the utilities involved in the IEEE benchmark survey have gone to something other than midnight-to-midnight. Some will “roll” the 24 hours to more accurately capture the full impact of a storm day (and possible MED). This option was implemented by NWE in 2015.

NorthWestern Energy has an active relationship with the IEEE Power and Energy Society Reliability Working Group to ensure a consistent and accurate portrayal of our utility's ability to report and benchmark reliability indices. MEDs are identified through a monthly process for each region and can be included or excluded per the data requested. This report will provide all information, including and excluding MEDs, for all three indices to better demonstrate and analyze normal versus emergency conditions. In 2015, there were five Major Event Days. By comparison, there was one MED in 2009, one in 2010, none in 2011, two in 2012, two in 2013 and none in 2014. Please see table below listed in descending SAIDI Minutes. For the Montana region, it took 6.31 SAIDI minutes in 2015 to declare an MED. Historically in Montana, a larger MED event could be 20 SAIDI minutes or more.

Date/Time MED Started	SAIDI Minutes	Cause
8/11/2015 0:10	81	Extreme wind storm hit the Missoula area
11/17/2015 11:00	22	Extreme wind storm affected the entire Montana region.
7/4/2015 12:11	13	Strong wind/rain storm in the Great Falls and Havre areas
3/28/2015 14:54	8	Strong wind and substation problem
8/10/2015 0:10	8	Extreme wind storm hit the Missoula area

Table 1: Major Event Days (2015)

Due to the very large SAIDI contribution of the August 11 MED, it was also determined to be a “Catastrophic Day.” It takes seven times the MED threshold, or 44.17 SAIDI minutes to declare a “Catastrophic Day.”

Transmission related reliability data and graphs have been added as an annex to the report again this year.

1. GENERAL

1.1 Reliability indices calculation

The calculation of SAIDI and CAIDI, (in minutes) and SAIFI (in outages per customer) are based on the following IEEE formulas:

$$SAIDI = \frac{\text{sum of all customer outage durations(minutes)}}{\text{total number of customers served}}$$

$$SAIFI = \frac{\text{total number of customers experiencing outages}}{\text{total number of customers served}}$$

$$CAIDI = \frac{\text{sum of all customer outage duration(minutes)}}{\text{total number of customers experiencing outages}} = \frac{SAIDI}{SAIFI}$$

In laymen’s terms, SAIDI represents the average outage in minutes for each customer served. SAIFI is the average number of interruptions that a customer would typically experience in a year. CAIDI is the average outage duration any given customer would experience. CAIDI is also typically thought of as the average restoration time.

1.2 Additional Notable Events

There were three days with a “Customer-Minutes Interrupted” (CMI) number greater than one million (an MED for 2015 required 2.21 million CMI). Please see table below, listed in descending CMI. These storm events, while not being MEDs, added significantly to the SAIDI minutes for 2015. For comparison, there were four days in 2014 with over a million CMI.

Date	CMI	Divisions impacted	Majority Causes
10/11/2015	1,390,687	Bozeman, Butte, Great Falls, Helena, Missoula	Wind, Equipment Failure, Tree In Line
7/23/2015	1,261,371	Butte	Tree In Line, Wind, Lightning
8/13/2015	1,055,416	Hamilton, Missoula	Human Error/Accident, Tree In Line

Table 2: Additional Notable Events (2015)

Further details on these events are provided in the operating area discussions below.

2. MONTANA SYSTEM RELIABILITY




Figure 2.1 Montana system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

The figure above displays NorthWestern Energy's Montana region indices for the years 2012-2015. Region indices shown for 2012 to 2015 data (excluding MEDs) are from year-end audited data (excluding MEDs). Please note that SAIDI and CAIDI are given in minutes and SAIFI is given in the frequency of occurrence.

As can be seen by **Figure 2.1**, 2015 SAIDI and SAIFI were higher than 2014, while CAIDI improved slightly. Also, all three indices in 2014 were lower than the previous three-year averages. In 2015, NWE saw a high number of wind storms, most dramatically a mid-August extreme wind storm in the Missoula area over a three day period, but also a high number of storms in Great Falls and Havre.

Contributing factors to the decrease reliability will be discussed as each of the operating divisions of the Montana region are examined and in the report conclusion. Data and figures are presented that characterize the system reliability both including and excluding MEDs to demonstrate the effect MEDs had on the system reliability in previous years.

Montana System Indices (Including MEDs)




Figure 2.2 Montana system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

SAIDI increases 131 minutes as shown in 2015 when the five MEDs are included in the reliability index. Also, CAIDI and SAIPI increase noticeably.

Outages by cause (excluding MEDs) are shown in **Figure 2.3**.

Montana - Outages By Top Ten Causes (Excluding MEDs)




Figure 2.3 Montana system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

The outage causes represented in this table are the top ten major contributors for customer outages on the NorthWestern Energy Electric Distribution and Transmission system. Overall outages reported increased 43% to 8758. A significant increase was expected due to the more accurate data collected by the Outage Management System (OMS) that entered service in the fourth quarter of 2014. For example, outage counts for scheduled maintenance increased noticeably. In the past, small planned outages, where the crew notified the customers of the pending outage were not well documented but they are now. Scheduled Maintenance increased by 1804 outages. This increase is due to the previously mentioned OMS and the increased work as part of the DSIP program. This had a significant impact of 9.9 minutes or 4.17% of Montana Region SAIDI. It is now one of the top ten outages causes in each division/district in Montana.

The top ten outage counts increased from 5157 in 2014 to 7656 in 2015. Nature related outages such as wind, lightning and snow/ice went down by 605 outages. Overall Equipment Failure outages increased 642. Equipment Failure is the most common of the unscheduled outage causes due to its broad and all-inclusive category nature. Outages can be related back to Equipment Failure in many different ways and it is the responsibility of the operations personnel to correctly identify the cause.

Montana - Outages By Top Ten Causes (Including MEDs)




Figure 2.4 Montana system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

The graph and table above show outage causes with MEDs. As stated above, the five Major Event Days reported were due largely to strong windstorms which accounted for 170 outages in the wind category. Most of the outage categories in 2015 have increased when comparing them to 2014 numbers. A portion of this increase was due to the OMS implementation as well as the catastrophic day in the Missoula area.

3. BILLINGS SYSTEM RELIABILITY

For Billings, SAIDI and CAIDI increased in 2015. SAIFI decreased slightly. The increase in SAIDI and CAIDI was expected due to the OMS implementation. SAIDI and SAIFI are less than their three-year averages. Storm problems were about the same from 2014 and although equipment outage counts were up, the SAIDI impact was lower. Larger outages for the year were caused by equipment failures in the Billings Meridian and Shiloh substations. Squirrels and Other Birds still cause a large number of outages, and tree problem outages are down considerably, most likely due to increased trimming efforts.




Figure 3.1 Billings system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Billings System Indices (Including MEDs)




Figure 3.2 Billings system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Billings - Outages By Top Ten Causes (Excluding MEDs)




Figure 3.3 Billings system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Billings - Outages By Top Ten Causes (Including MEDs)




Figure 3.4 Billings system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

4. BOZEMAN SYSTEM RELIABILITY

Bozeman division indices for 2015 saw significant a increase in SAIDI and CAIDI from 2014 but a decrease in SAIFI. Like Billings, a portion of these increases were expected by the OMS implementation. Larger events in the area were a vehicle hitting a guy wire causing Jackrabbit Ckt. # 72 to trip and a wind storm, during an MED, tripped out a transmission line resulting in loss of service to all customers fed from the Harrison/Pony Substation. Equipment failure outage counts were essentially unchanged, but tree and animal related outage counts increased appreciably.




Figure 4.1 Bozeman system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Bozeman System Indices (Including MEDs)




Figure 4.2 Bozeman system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Bozeman - Outages By Top Ten Causes (Excluding MEDs)




Figure 4.3 Bozeman system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.




Figure 4.4 Bozeman system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

5. BUTTE SYSTEM RELIABILITY

For 2015, SAIDI and SAIFI increased and CAIDI held about the same for the Butte Division. The Butte division numbers were also increased due to the OMS. Lightning struck a tree causing it to fall into two feeders out of the Continental Drive Substation and current transformer failures in the Laurin Substation were the two largest single events for the division. Equipment outages were essentially unchanged for Butte. There was a large increase in animal related outages and bird related outages in particular. Tree outages also increased, likely from more severe wind for the year.




Figure 5.1 Butte system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Butte System Indices (Including MEDs)




Figure 5.2 Butte system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Butte - Outages By Top Ten Causes (Excluding MEDs)




Figure 5.3 Butte system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Butte - Outages By Top Ten Causes (Including MEDs)




Figure 5.4 Butte system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

6. GREAT FALLS SYSTEM RELIABILITY

Great Falls Division saw a decrease in SAIDI and CAIDI and a slight decrease in SAIFI for 2015. Animal related and lightning caused outages greatly increased. The number of equipment failures also increased. Strong winds contributed to many of the failures. This reflects the large impact of weather in 2015. Great Falls was greatly affected by three MEDs in 2015. Surprisingly, the number of Vehicle Hit outages also had a large increase. The larger outages for the division were a vehicle hit a transmission structure that fell into a distribution line, a tree got into Great Falls City CKT #34, and relaying problem in the Great Falls Riverview Substation.




Figure 6.1 Great Falls system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Great Falls System Indices (Including MEDs)




Figure 6.2 Great Falls system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Great Falls - Outages By Top Ten Causes (Excluding MEDs)




Figure 6.3 Great Falls system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Great Falls - Outages By Top Ten Causes (Including MEDs)




Figure 6.4 Great Falls system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

7. HAVRE SYSTEM RELIABILITY

Havre saw a slight increase in SAIDI and a larger increase in CAIDI. SAIFI was reduced almost a full minute. SAIDI and SAIFI were lower than the three year averages. Larger outages were a transmission problem that took out the Havre Highland Park Substation and a transmission pole failure that took out Havre Eastside Substation. Non-MED storm related outages were notably down, animal and equipment failures were notably higher. Storm caused MEDs had a large impact on the Havre area.

Havre System Indices (Excluding MEDs)





Figure 7.1 Havre system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Havre System Indices (Including MEDs)



Year

Figure 7.2 Havre system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Havre - Outages By Top Ten Causes (Excluding MEDs)




Figure 7.3 Havre system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Havre - Outages By Cause (Including MEDs)




Figure 7.4 Havre system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

8. HELENA SYSTEM RELIABILITY

Helena Division saw an increase of all three indices for 2015 over 2014 values. Like other divisions, the OMS implementation had a significant impact. The Mont. Ave. South Fdr. 2 had a major outage caused by a tree falling into the line and breaking a crossarm. Human error caused an outage on the East Valley Fdr. 63. And a transmission problem resulted in the loss of service to Clancy Substation. Equipment failure and animal outages were higher.




Figure 8.1 Helena system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Helena System Indices (Including MEDs)




Figure 8.2 Helena system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Helena - Outages By Top Ten Causes (Excluding MEDs)




Figure 8.3 Helena system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Helena - Outages By Top Ten Causes (Including MEDs)




Figure 8.4 Helena system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

9. LEWISTOWN SYSTEM RELIABILITY

Lewistown District saw an increase in all three indices in 2015. Even with these increases, a SAIDI of 86 minutes and SAIFI of 0.76, it was still a very reliable year! Larger outages were an cutout and insulator failure at the Moccasin Substation caused by a raccoon and an transmission problem with an unknown cause.. Wind related outages were significantly down, but animals are making a comeback. Equipment failure outages doubled.




Figure 9.1 Lewistown system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Lewistown System Indices (Including MEDs)




Figure 9.2 Lewistown system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Lewistown - Outages By Top Ten Causes (Excluding MEDs)




Figure 9.3 Lewistown system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Lewistown - Outages By Top Ten Causes (Including MEDs)




Figure 9.4 Lewistown system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

10. MISSOULA SYSTEM RELIABILITY

Excluding MEDs, the Missoula Division improved the SAIDI and CAIDI indices in 2015. There was a significant increase in SAIFI. The OMS implementation has a significant impact. Missoula experienced the largest impact from MEDs. Two, on August 10th and August 11th, were primarily concentrated in Missoula. The August 11th MED was the largest ever in the Montana Region, contributing 81 SAIDI minutes! Total contribution of both MEDS was 89 minutes. The largest non-MED event was a broken cutout Plains Fdr #1 on August 22nd that caused almost one MT SAIDI minute. Earlier in August, a relay failure in the Missoula Industrial sub also caused a large outage. Also in August, a lightning storm too out Target Range Fdr 71. August was not a good month for Missoula! Tree related outages were down, while equipment, animal, and wind outages were up.




Figure 10.1 Missoula system indices excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Missoula System Indices (Including MEDs)




Figure 10.2 Missoula system indices including major event days (MEDs) as defined in IEEE Standard 1366-2012.

Missoula - Outages By Top Ten Causes (Excluding MEDs)




Figure 10.3 Missoula system outages by top ten causes excluding major event days (MEDs) as defined in IEEE Standard 1366-2012.

Missoula - Outages By Top Ten Causes (Including MEDs)




Figure 10.4 Missoula system outages by top ten causes including major event days (MEDs) as defined in IEEE Standard 1366-2012.

11. CONCLUSION

Last year started off well with SAIDI being below the three year average until the MED on July 4th. This was caused by a strong wind and rain storm in the Great Falls and Havre areas. This drove that month's SAIDI over 19 minutes, compared to an earlier three-year July average of 14 minutes. With fairly average interruptions from July 4th to August 10th, SAIDI remained higher than average. But then the Missoula MEDs occurred, that added 89 minutes to Montana SAIDI. The remaining months were generally better than their corresponding three year average. The result was a year-end SAIDI, without MEDs, of 129 compared to the three year average of 124. The year-end SAIDI, with MEDs, was 260. This is the largest Montana SAIDI in company history.

The InService mobile work force and outage management system was implemented by NWE during the fall of 2014. This provided more accurate and timely outage reporting for 2015. Outage customer counts and times are derived from the GIS, call logging, and automated systems, eliminating the earlier manual outage reporting system and its inherent approximations. This was well illustrated in 2015 with the large increase in Scheduled Construction and Maintenance outages. In the past, many of these outages were not reported. Both IEEE and the Department of Energy reports indicate that SAIDI numbers normally increase with this improved accuracy, but with the whims of nature, this may be difficult to determine for some time. The conversion to The IEEE reliability standard (1366-2012) does not define the 24 hour day and many of the utilities involved in the IEEE benchmark survey have gone to something other than midnight-to-midnight. Some will even "roll" the 24 hours to more accurately capture the full impact of a storm day (and possible MED). This option was implemented by NWE in 2015.

Increased efforts in line patrol and repairs as well as vegetation work may have improved reliability in 2015, as well as reduced the impacts from larger storms. Additionally, with the implementation of reliability projects under the Distribution System Infrastructure Project (DSIP), stability and hopefully improvement in electric system reliability should be realized. Of course the impacts of storms are a major contributor to reduced reliability and complicate any analysis. Substation and other asset improvements increased scheduled outages, but careful planning kept these outages to a minimum and this work helps avoid equipment failures and provides facilities to serve future loads. With continued upgrades and planning, diligent work, and sincere effort, NorthWestern Energy strives to provide safe, reliable electric service to our customers and a safe working environment for our employees, now and into the future.

ANNEX A: TRANSMISSION DATA AND GRAPHS

Attached below are graphs showing the electric transmission cumulative outage duration, cumulative outage frequency, ASAI and SAIFI. A graph for 2015 is given for each metric. Also a graph showing data from 2002 to 2015 is given for ASAI and SAIFI. Graphs showing the 2012-2014 average and 2015 year end are provided. Also included are graphs showing the outage cause duration and frequency by year from 2011 through 2015.

The 2015 outage duration is approximately **287 hours (17.3%) less** than the 2012-2014 average. The 2014 outage frequency (count) is approximately **48 outages (6.7%) more** than the 2012-2014 average. These numbers reflect a very reliable year at the transmission level. Terminal Equipment, Hardware, and Unknown outage numbers were all down from 2015, with Weather and Tree outages notably up in 2015.

Outage Duration - Hours													
Year		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2015	Monthly	20.89	185.73	107.21	105.61	47.40	126.22	218.31	81.36	48.27	44.85	304.05	81.35
2012-2014	Monthly	103.32	92.18	98.97	139.71	155.37	134.41	247.32	176.24	133.91	167.75	87.17	121.48
2015	Cumulative	20.89	206.63	313.84	419.45	466.85	593.07	811.37	892.74	941.00	985.86	1289.90	1371.25
2012-2014	Cumulative	103.32	195.50	294.48	434.19	589.55	723.96	971.27	1147.51	1281.42	1449.17	1536.34	1657.82

Outage Frequency - Count													
Year		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2015	Monthly	32.0	64.0	51.0	65.0	66.0	79.0	94.0	115.0	43.0	57.0	44.0	55.0
2012-2014	Monthly	41.7	35.7	45.7	70.7	66.3	91.7	105.0	76.7	59.0	48.3	34.0	42.0
2015	Cumulative	32.0	96.0	147.0	212.0	278.0	357.0	451.0	566.0	609.0	666.0	710.0	765.0
2012-2014	Cumulative	41.7	77.3	123.0	193.7	260.0	351.7	456.7	533.3	592.3	640.7	674.7	716.7

ASAI (Average Service Availability Index) - % Larger is Better													
Year		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2015	Monthly	99.990	99.904	99.950	99.949	99.978	99.939	99.898	99.962	99.977	99.979	99.854	99.962
2012-2014	Monthly	99.950	99.952	99.952	99.931	99.925	99.933	99.881	99.915	99.934	99.920	99.957	99.942
2015	Cumulative	99.990	99.949	99.950	99.949	99.955	99.953	99.945	99.947	99.950	99.953	99.944	99.946
2012-2014	Cumulative	99.950	99.951	99.951	99.946	99.942	99.941	99.932	99.930	99.930	99.929	99.932	99.932

SAIFI (System Average Interruption Frequency) - Smaller is Better													
Year		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2015	Monthly	1.308	2.897	2.085	2.746	2.698	3.327	3.830	4.685	1.810	2.322	1.852	2.241
2012-2014	Monthly	1.754	1.642	1.922	3.077	2.793	3.987	4.419	3.227	2.566	2.031	1.475	1.764
2015	Cumulative	1.308	2.062	2.070	2.239	2.333	2.498	2.694	2.948	2.823	2.772	2.689	2.651
2012-2014	Cumulative	1.754	1.701	1.777	2.101	2.243	2.531	2.807	2.860	2.828	2.747	2.632	2.559




Figure A.1 Electric transmission cumulative outage duration - 2015




Figure A.2 Electric transmission cumulative outage frequency - 2015




Figure A.3 Electric transmission Average Service Availability Index (ASAI) - 2015



Figure A.4 Electric transmission Average Service Availability Index (ASAI) 2002-2015




Figure A.5 Elect. Transmission System Average Interruption Frequency Index (SAIFI) - 2015




Figure A.6 Elect. Trans. System Average Interruption Frequency Index (SAIFI) 2002 - 2015




Figure A.7 Comparison of 2015 outage duration to previous three-year average




Figure A.8 Comparison of 2015 outage frequency to previous three-year average




Figure A.9 Outage duration by cause by year for 2011-2015




Figure A.10 Outage frequency by cause by year for 2011-2015

CERTIFICATE OF SERVICE

I hereby certify that NorthWestern Energy's 2015 Annual Electric Reliability Report has been hand delivered to the Montana Public Service Commission this date. It has also been e-filed on the MPSC website.

Date: March 1, 2016



Pam LeProwse
Administrative Assistant
Regulatory Affairs